

## Central Carolina Community College - Civic Center Light Fixture Schedule

Fixture Designation	Description [XA = Existing, A = Replacement]	Lamp Quantity	Fixture Wattage	Fixture Quantity
A	INTENT: Retrofit 2'x4', 4 Lamp T12 Troffer with... 2'x4', 2 Lamp T8 Retrofit Kit, WO Reflector, HBF. [OPT TR 24 232 UV 1HI B 841ADV]	2	75	42
B	INTENT: Retrofit 1'x4', 2 Lamp T12 Troffer with... 1'x4', 1 Lamp T8 Retrofit Kit, WO Reflector, HBF. [OPT TR 14 132 UV 1HI B 841ADV]	1	45	42
C	INTENT: Relamp/Reballast 4', 2 Lamp T12 Vapor Tight with... 2 Lamp T8 Ballast, LBF + F32T8 High Lumen Lamps, 5000K. [See "Other Equipment Costs" Table]	2	47	8
D	INTENT: Replace 4', 2 Lamp T12 Industrial Strip with... 4', 1 Lamp T8 Retrofit Kit, White Reflector, HBF. [OPT SRSB A 132 UV 1HI W 850ADV]	1	45	38
E	INTENT: Replace 4', 2 Lamp T12 Stairwell with... New 4', 1 Lamp T8 Vanity, Silver Reflector, HBF. [OPT VL 132 UV 1HI E 850ADV]	1	45	6
F	INTENT: Retrofit 200w Incandescent Can with... 2x42w CFL Retrofit Can. [Elite HHR6PL-2x42-E-MVOLT-6501-W-WH]	2	92	60
G	INTENT: Retrofit 100w Mercury Vapor Can with... 2x32w CFL Retrofit Can. [Elite HHR6PL-2x32-E-MVOLT-6501-W-WH]	2	72	34
H	INTENT: Replace 400w Metal Halide Fixture with... New 4', 4 Lamp T5HO High-Bay, Hanging Cable, 6' Cord. [OPT G10 454 CSB E QC C6 850ADV CC(BL)]	4	235	60
I	INTENT: Remove 200w Incandescent Can - DO NOT REPLACE! (Small Auditorium)	0	0	13
J	INTENT: Replace 400w Metal Halide Fixture with... New 4', 4 lamp T5HO High-Bay, Hanging Cable, 6' Cord. [OPT G10 454 CSB E QC C6 850ADV CC(BL)]	4	235	12
K	INTENT: Remove 8', 2 Lamp T12 Strips - DO NOT REPLACE! (Large Auditorium)	0	0	9
L	INTENT: Replace 150w Metal Halide Dock Lights with... New 2', 3 Lamp T5 Wall-Mount [ILP WM-3T5-UH-U850]	3	76	6
XA	EXISTING (TYPE A, B) 2'X4', 4L T12 TROFFER	4	148	42
XB	EXISTING (TYPE C, D) 1'X4', 2L T12 TROFFER	2	72	42
XC	EXISTING (TYPE G, H) 4', 2L T12 VAPOR-TIGHT	2	72	8
XD	EXISTING (TYPE J, K) 4', 2L T12 INDUSTRIAL	2	72	38
XE	EXISTING (TYPE L) 4', 2L T12 STAIRWELL	2	72	6
XF	EXISTING (TYPE P, R) 200w INCAND. CAN	1	200	60
XG	EXISTING (TYPE S) 100w MERCURY VAPOR	1	125	34
XH	EXISTING (TYPE T, U) 400w MH HID	1	458	60
XI	EXISTING (TYPE V) 200w INCAND. CAN	1	200	13
XJ	EXISTING (TYPE W) 400w MH HID	1	458	12
XK	EXISTING 8', 2L T12 STRIP	2	115	9
XL	EXISTING 150w MH LOADING DOCK LIGHTS	1	185	6

